

Consumer Confidence Report

Belmont Water Department

EPA # 0201010

2020

What is a Consumer Confidence Report?

The Consumer Confidence Report (CCR) details the quality of your drinking water, where it comes from, and where you can get more information. This annual report documents all detected primary and secondary drinking water parameters and compares them to their respective standards known as Maximum Contaminant Levels (MCLs).

NOW IT COMES WITH A LIST OF INGREDIENTS.



The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also, come from gas stations, urban storm water runoff, and septic systems.

Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the EPA prescribes regulations which limit the amounts of certain contaminants in water provided by public water systems. The US Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

What is the source of my drinking water? The water that supplies Belmont comes from three gravel packed wells located on the Town owned Lot 31 on Shaker Road in the area of Pout Pond. Well 1 is east next to Shaker Rd; Well 2 is west closer to the pond; Well 3 is 470' west of pumphouse. The water from Well # 3 is treated with a 25% solution of Caustic Soda to raise the pH from a natural 6.0 to 7.4. We also treat for Iron and Manganese with a sequestering agent of Ortho-Polyphosphate. This keeps an unpleasant color or staining from occurring.

Why are contaminants in my water? Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Do I need to take special precautions? Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC

guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at 1-800-426-4791.

Source Water Assessment Summary

DES prepared drinking water source assessment reports for all public water systems between 2000 and 2003 in an effort to assess the vulnerability of each of the state's public water supply sources. Included in the report is a map of each source water protection area, a list of potential contamination sources, and a summary of available protection options.

Source Name	Date	High	Med	Low
GPW # 1	4/17/00	1	3	8
GPW # 2	4/17/00	1	2	9
GPW # 3	Not Rated			

Note: This information is over 19 years old and includes information that was current at the time the report was completed. Therefore, some of the ratings might be different if updated to reflect current information. At the present time, DES has no plans to update this data.

The complete Assessment Report is available for review. For more information, call *Donald Hurd* at 603-267-8300 x 120 or visit the DES Drinking Water Source Assessment website at <http://des.nh.gov/organization/divisions/water/dwgb/dwspp/dwsap.htm>.

How can I get involved?

For more information about your drinking water please call Donald Hurd at 603-267-8300 x120.

Violations: We are pleased to announce there were no violations.

Health Effects

Lead: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. This water

system is responsible for high quality drinking water but, cannot control the variety of materials used in your plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing cold water from your tap for at least 30 seconds to 2 minutes before using water for drinking or cooking. Do not use hot water for drinking and cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at 800-426-4791 or at <http://water.epa.gov/drink/info/lead>.

Sodium: Sodium sensitive individuals such as those experiencing hypertension, kidney failure, or congestive heart failure, who drink water containing sodium, should be aware of levels where exposures are being carefully controlled.

Definitions

Action Level or AL: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Abbreviations

NA: Not Applicable

ND: Not Detectable at testing limits

pCi/L: picoCurie per Liter

ppt: parts per trillion

ppb: parts per billion

ppm: parts per million

90th Percentile – Out of every 10 homes sampled, 9 were at or below this level

Data 2019

Inorganic Contaminants	Year Collected	Highest Detect	Range Detected	MCL	MCLG	Violation Yes/No	Typical Source of Contaminant
Barium (ppm)	2017-2019	0.022	0.0042-0.022	2	2	No	Geological; oil/gas drilling, painting, industrial waste
Chloride (ppm)	2017-2019	139	30-139	Not Regulated	250	NA	Wastewater, road salt, water softeners, corrosion
Nitrate as Nitrogen (ppm)	2019	1.46	0.29-1.46	10	10	No	Geological; fertilizer, sewage. Feedlots
Chromium (ppb)	2017-2019	1.5	ND-1.5	100	100	No	Discharge from steel and pulp mills; erosion of natural deposits
Sodium (ppm)	2017-2019	72.0	26.9-72.0	Not Regulated	100-250	NA	Road salts, septic systems (salt from water softeners)
Iron (ppm)	2017-2019	2.50	0.81-2.50	Not Regulated	0.30	NA	Erosion of natural deposits: corrosion of cast iron pipes
Manganese (ppb)	2017-2019	152	48-152	Not Regulated	50	NA	Erosion of natural deposits
Synthetic Organic Contaminants							
Di (2-ethylhexyl) phthalate (ppb)	2016	1.2	ND-1.2	6	0	No	Discharge from rubber and chemical factories
Radiological Contaminants							
Compliance Gross Alpha (pCi/L)	2016	2	ND - 2	15	0	No	Erosion of natural deposits
Radium 226 & 228 (pCi/L)	2016	0.7	0.3 – 0.7	5	0	No	Erosion of natural deposits
Year Collected	90th Percentile	Action Level	MCLG	# of Sites Sampled	# Sites Above Action Level	Violation Yes/No	Typical Source of Contaminant
Copper (ppm)	2019	0.24	1.3	10	0	No	Corrosion of household plumbing system